

Efficiency Matrix Pty Ltd

Downlight Mitts

“Downlight Mitt” Acoustic Test Report

**Vipac Engineers & Scientists Ltd**

279 Normanby Road, Private Bag 16  
Port Melbourne VIC 3207  
t. +61 3 9647 9700 | f. +61 3 9646 4370  
[www.vipac.com.au](http://www.vipac.com.au)

Document No.  
30B-11-0090-TRP-595139-1  
23 May 2011

## DOCUMENT CONTROL

| Downlight Mitts<br>"Downlight Mitt" Acoustic Test Report   |  |
|--|--|
| DOCUMENT NO.:<br>30B-11-0090-TRP-595139-1                  | LIBRARY CODE:  |
| PREPARED FOR:<br>14 Ondine Drive<br>Wheelers Hill Vic 3150 | PREPARED BY:<br>Vipac Engineers & Scientists Ltd<br>279 Normanby Road, Private Bag 16<br>Port Melbourne VIC 3207 |
| Contact: John Konstantakopoulos<br>☎: 0434 195 792<br>Fax: | Contact: Darren Tardio<br>☎: +61 3 9647 9700<br>Fax: +61 3 9646 4370   |

| PREPARED BY:      | Darren Tardio<br>Acoustic Project Engineer  | 27 May 2011     |                |             |                 |                             |             |               |
|-------------------|---|-----------------|----------------|-------------|-----------------|-----------------------------|-------------|---------------|
| REVIEWED BY:      | Dr Marc Buret<br>Senior Acoustic Consultant   | 27 May 2011     |                |             |                 |                             |             |               |
| RELEASED BY:      | Darren Tardio<br>Acoustic Project Engineer  | 27 May 2011     |                |             |                 |                             |             |               |
| REVISION HISTORY: | <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Revision No.</th> <th style="width: 40%;">Date Issued</th> <th style="width: 30%;">Reason/Comments</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">0</td> <td style="text-align: center;">23 May 2011</td> <td>Initial Issue</td> </tr> </tbody> </table> |                 | Revision No.   | Date Issued | Reason/Comments | 0                           | 23 May 2011 | Initial Issue |
| Revision No.      | Date Issued   | Reason/Comments |                |             |                 |                             |             |               |
| 0                 | 23 May 2011   | Initial Issue   |                |             |                 |                             |             |               |
| DISTRIBUTION:     | <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Copy No. _____</th> <th style="width: 80%;">Location</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td>Vipac - Project/Client File</td> </tr> <tr> <td style="text-align: center;">2</td> <td>Original</td> </tr> </tbody> </table>              |                 | Copy No. _____ | Location    | 1               | Vipac - Project/Client File | 2           | Original      |
| Copy No. _____    | Location  |                 |                |             |                 |                             |             |               |
| 1                 | Vipac - Project/Client File   |                 |                |             |                 |                             |             |               |
| 2                 | Original  |                 |                |             |                 |                             |             |               |
| KEYWORDS:         |   |                 |                |             |                 |                             |             |               |

NOTE: This is a controlled document within the document control system. If revised, it must be marked SUPERSEDED and returned to the Vipac QA Representative.

This document contains commercial, conceptual and engineering information which is proprietary to Vipac Engineers & Scientists Ltd. We specifically state that inclusion of this information does not grant the Client any license to use the information without Vipac's written permission. We further require that the information not be divulged to a third party without our written consent.

## TABLE OF CONTENTS

|                                      |    |
|--------------------------------------|----|
| 1. INTRODUCTION.....                 | 4  |
| 2. TESTING STANDARD & PROCEDURE..... | 4  |
| 3. TEST RESULTS.....                 | 7  |
| 3.1. Sound Pressure Levels.....      | 7  |
| 3.2. Insertion Loss.....             | 8  |
| 3.3. Transmission Loss.....          | 9  |
| 3.4. Tabulated Data.....             | 10 |
| 4. CONCLUSION.....                   | 10 |

## 1. INTRODUCTION

Vipac Engineers & Scientists Ltd (VIPAC) has been engaged by Efficiency Matrix to test the acoustic performance of the Downlight Mitt. All tests were conducted using a Galaxy Ø90mm low voltage downlight kit supplied by Efficiency Matrix. The test certifies the acoustic Insertion Loss (dB) of the specimen and composite Transmission Loss of plasterboard, light and mitt, which may be deemed useful when comparing to a homogenous plasterboard finish.

## 2. TESTING STANDARD & PROCEDURE

We note that no specific standard exists for testing the performance of downlight covers, however procedures that determine the acoustic Insertion Loss (dB) and Transmission Loss (dB) of the product have been deemed by the engineer as appropriate performance measures. The testing is derived from the general and technical requirements of International Standards ISO 140-10 Acoustics -- Measurement of sound insulation in buildings and of building elements -- Part 10: Laboratory measurement of airborne sound insulation of small building elements and ISO 11691 Acoustics -- Measurement of insertion loss of ducted silencers without flow -- Laboratory survey method.

While the first provides the background and requirement for sound insulation requirements including Sound Transmission Loss, the latter documents the Insertion Loss, which is a useful index for describing the performance of the specimen alone.

All tests were carried out in Vipac's Reverberation Chambers. The Ø90mm downlight specimen was installed in 16mm Fire-rated plasterboard (13kg/m<sup>2</sup>). The plasterboard panel was installed in a 1.2m x 1.2m aperture between the two chambers. The mitt was installed following the recommendations of the manufacturer within the source chamber. A pink noise signal was generated in the source chamber and 1/3 Octave Band sound level measurements were conducted in the receiving chamber at six (6) diffuse points, which were then averaged. Frequency analysis was conducted between 100Hz and 10,000Hz.




Figure 2.1: Vipac's Reverberation Chambers

The following measurements were conducted:

- Average Sound Pressure Level in the source chamber ( $L_s$ )
- Average Sound Pressure Level in the receiving chamber with downlight (no mitt) installed ( $L_{R1}$ )
- Average Sound Pressure Level in the receiving chamber with downlight and Downlight Mitt installed ( $L_{Rn}$ )
- Average Sound Pressure Level in the receiving chamber with plasterboard fill installed ( $L_{Rn}$ )

Insertion Loss was determined by the following equation:

$$IL = L_{R1} - L_{Rn} \text{ (dB)}$$

Transmission Loss was determined by the following equation:

$$TL = L_s - L_R + 10 \log_{10} (S/A) \text{ (dB)}$$

where

$S$  = Area of the test specimen, here  $S = 1.44\text{m}^2$

$A$  = Equivalent absorption area in the receiving room, determined by reverberation time measurements

All tests were performed with a NATA calibrated Bruel & Kjaer 2250 Type-1 Precision Sound Level Meter and Frequency Analyser. Instrumentation was also checked for calibration with a Bruel & Kjaer 4230 calibrator before and after the measurements. No significant drift was observed.

Background noise measurements were also made within the reverberation laboratory during testing. Levels were found to be at least 15 dB below the measured noise signal levels demonstrating that background noise did not affect the measurements.

The testing environment was also monitored for temperature, humidity and atmospheric pressure deviations over the course of the measurements and no significant drift was noted.

The test installation is illustrated in Figures 2.2 and 2.4.



Figure 2.2: Downlight installation in plasterboard (from receiving chamber)



Figure 2.3: Downlight Mitt (covering downlight) installation on plasterboard (from source chamber)




Figure 2.4: 16mm plasterboard fill installation, from receiving and source rooms respectively

### 3. TEST RESULTS

#### 3.1. Sound Pressure Levels

Figure 3.1.1 shows the average receiving chamber Sound Pressure Levels. In comparison to the 90mm light and plasterboard composite installation, the average Noise Reduction (defined here as the Pink Noise SPL reduction with reference to plasterboard with light fitting only) for the 16mm Plasterboard, 90mm downlight and Downlight Mitt was 2dB(A). The average Noise Reduction for the 16mm Plasterboard fill was 3dB(A).




Figure 3.1.1: Average SPL difference of measurements

### 3.2. Insertion Loss

Figure 3.2.1 shows the Insertion Loss (dB) for the specimen and plasterboard fill, compared with the 90mm light and plasterboard composite installation.




Figure 3.2.1: Insertion Loss values



### 3.3. Transmission Loss

Figure 3.3.1 shows the Transmission Loss (dB) for the specimen. The composite Weighted Sound Reduction Index, as determined in accordance with ISO 717.1 and considered relevant for the 16mm Plasterboard, 90mm downlight and Downlight Mitt was  $R_w = 33\text{dB}$ . The Weighted Sound Reduction Index for the 16mm Plasterboard alone was  $R_w = 34\text{dB}$ .




Figure 3.3.1: Transmission Loss values

### 3.4. Tabulated Data

The tabulated Insertion Loss (dB) and Transmission Loss (dB) values are:

| <u>1/3 Octave Band<br/>Frequency</u> | <u>Downlight Mitt w/ 90mm downlight</u> |                                 | <u>Plasterboard Fill</u>     |                                 |
|--------------------------------------|---|---------------------------------|------------------------------|---------------------------------|
|                                      | <u>Insertion Loss<br/>dB</u>            | <u>Transmission Loss<br/>dB</u> | <u>Insertion Loss<br/>dB</u> | <u>Transmission<br/>Loss dB</u> |
| 100Hz                                | 0.8                                     | 17.6                            | 2.3                          | 19.1                            |
| 125Hz                                | 0.8                                     | 19.0                            | 1.5                          | 19.7                            |
| 160Hz                                | 1.0                                     | 21.5                            | 1.1                          | 21.6                            |
| 200Hz                                | 0.0                                     | 22.8                            | 1.6                          | 25.1                            |
| 250Hz                                | 1.4                                     | 27.5                            | 1.9                          | 28.1                            |
| 315Hz                                | 1.2                                     | 27.6                            | 3.0                          | 29.4                            |
| 400Hz                                | 2.0                                     | 30.5                            | 3.0                          | 31.5                            |
| 500Hz                                | 2.8                                     | 31.6                            | 2.7                          | 31.5                            |
| 630Hz                                | 5.4                                     | 33.6                            | 5.4                          | 33.5                            |
| 800Hz                                | 6.9                                     | 34.6                            | 7.2                          | 34.8                            |
| 1000Hz                               | 5.5                                     | 35.7                            | 6.4                          | 36.5                            |
| 1250Hz                               | 7.7                                     | 35.8                            | 8.3                          | 36.4                            |
| 1600Hz                               | 6.9                                     | 37.2                            | 6.7                          | 37.0                            |
| 2000Hz                               | 3.7                                     | 32.6                            | 3.4                          | 32.4                            |
| 2500Hz                               | 3.3                                     | 30.6                            | 3.2                          | 30.5                            |
| 3150Hz                               | 5.1                                     | 34.0                            | 4.8                          | 33.7                            |
| 4000Hz                               | 6.8                                     | 36.7                            | 6.2                          | 36.2                            |
| 5000Hz                               | 6.9                                     | 40.3                            | 6.0                          | 39.4                            |
| 6300Hz                               | 8.2                                     | R <sub>w</sub> = 33db           | 6.7                          | R <sub>w</sub> = 34dB           |
| 8000Hz                               | 11.5                                    |                                 | 8.4                          |                                 |
| 10000Hz                              | 15.7                                    |                                 | 11.8                         |                                 |

## 4. CONCLUSION

Under the test conditions documented in this report, the Downlight Mitt with 90mm downlight performs approximately equal to 16mm Fire-rated plasterboard at frequencies above 500Hz. The difference in Weighted Sound Reduction Index between the plasterboard panel with plasterboard fill and plasterboard panel with Downlight Mitt with 90mm downlight is found to be 1dB.